CERTIFICATE

No.: TM 61000464.001



VentiAir

Licence owner

VentiAir s.r.o. Adolfovice 512 790 01 Bela Pod Pradedem

Czech Republic

Manufacturing site

VentiAir s.r.o. Adolfovice 512 790 01 Bela Pod Pradedem Czech Republic

Project number

26100489

Our reference number

SD/84943954

Certificate validity period

from 29.01.2020 to 28.01.2025

Certification basis

PN-EN 13053+A1:2011

PN-EN 1886:2008

Type of product certification

3 wg. PN-EN ISO/IEC 17067

Certification program

PCBWTM

TÜV Rheinland Polska Sp. z o.o. hereby declares that the product described herein is consistent with the requirements of above mentioned reference documents:

Air handling and air conditioning units:

- Standard manufacture: W-TYPE, S-TYPE, V-TYPE, P-TYPE, K-TYPE, P-TYPE K, P-TYPE R, K-TYPE R, R-TYPE
- Hygienic grade: W-TYPE, S-TYPE, V-TYPE, P-TYPE, P-TYPE K, K-TYPE, R-TYPE,

Mechanical properties of the unit housing:

Stiffness of the housing

Air tightness of the housing in the overpressure and underpressure test Air leakage outside the filter in the overpressure and underpressure test

Thermal insulation of the housing

Share of thermal bridges in the model housing

class D1 (M)

class L1 (M)

class F9 (M)

class T2 (M)

class TB2 (M)

TÜV Rheinland Polska Sp. z o.o.

ul. 17 Stycznia 56

02-146 Warszawa, Poland Phone: (+48/22) 846 79 99 Phone: (+48/22) 868 37 42

E-mail: post@pl.tuv.com

Certification Body

Tomasz/paszowski

Warsaw, 29.01.2020

This certificate is subject to the Certificate Regulation and the General Terms and Conditions of Business of JCW TRP and refers solely to the products consistent with the specimen which serves as the basis for conformity assessment. The certificate itself does not authorise its owner to put the CE label on the product.

This certificate authorises its owner to put TÜV Safety label on the product.



Regular Production Surveillance Safety

www.tuv.com ID 0000073065





